

Sponsor

com2C GmbH & co. KG
Gaensekamp 37
32457 Porta Westfalica
Germany

Prepared by

Fire-Lab Sp. z o.o.
Ul. Szałwiowa 9
03-167 Warszawa, Polska

Product name

FloorGraphics 100 PP LUV M W

Classification report No.

RKS-1/07/2024

Issue number

Issue no. 1

Date of issue

30.07.2024

CLASSIFICATION OF REACTION TO FIRE IN ACCORDANCE WITH EN 13501-1:2019

This classification report consists of four pages and may only be used or reproduced in its entirety.

1. Introduction

This classification report defines the classification assigned to FloorGraphics 100 PP LUV M W in accordance with the procedures given in EN 13501-1:2019.

2. Details of classified product

2.1 General

The following product FloorGraphics 100 PP LUV M W is defined as floor graphics without protective film, trade fairs and store fixtured, advertising, soundproofing and aesthetics.

2.2 Product description

The product, FloorGraphics 100 PP LUV M W is described below or is described in the reports provided in support of classification listed in 3.1.

Product description (information below delivered by the sponsor):

Foil FloorGraphics 100 PP LUV M W air rem. Adh FR.

Foil consists of: PP (BOPP), reversible acrylic adhesive, injected PE paper – siliconized by one side. The surface of the foil is matte.

PP has thickness 100 µm.

Overall thickness is 280 µm (including PP, adhesive and cover)

End use:

- floor graphics without protective film,
- trade fairs and store fixtured,
- advertising,
- soundproofing and aesthetics.

Specimen tested on gypsum board substrate either stucked with adhesive layer.

3. Reports and results in support of this classification

3.1 Reports

Name of Laboratory	Name of sponsor	Report ref. no.	Test method and date
Fire-Lab sp z o.o.	com2C GmbH & co. KG	SBI-1/07/2024	PN-EN 13823+A1:2022-12 16.07.2024
Fire-Lab sp z o.o.	com2C GmbH & co. KG	MP-1/07/2024	PN-EN ISO 11925-2:2020 16.07.2024

3.2 Results

Test method and test number	Parameter	No. Tests	Results	
			Continuous parameter mean (m)	Compliance with parameters
PN-EN 13823+A1:2022-12 SBI-1/07/2024	FIGRA _{0,2MJ} [W/s]	3	167,67	(-)
	FIGRA _{0,4MJ} [W/s]		130,10	(-)
	LFS < edge		None	Compliant
	THR _{600s} [MJ]		2,16	(-)

	SMOGR _A [m ² /s ²]		0,00	(-)
	TSP _{500s} [m ²]		33,89	(-)
	Flaming droplets/particles		None	Compliant
PN-EN ISO 11925-2:2020 Surface exposure 30s MP-1/07/2024	F _s ≤150mm	6	F _s < 150mm	Compliant
	Flaming droplets/particles		None	Compliant
PN-EN ISO 11925-2:2020 Edge exposure 30s MP-1/07/2024	F _s ≤150mm	6	F _s < 150mm	Compliant

4. Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with EN 13501-1:2019

4.2 Classification

Products, Blockout LUVESSE SM W in relation to its reaction to fire behavior is classified:

C

The additional classification in relations to smoke production is:

s1

The additional classification in relation to flaming droplets / particles is:

d0

The format of the reaction to fire classification for construction products excluding floorings and linear pipe thermal insulation products is:

Reaction to fire classification: C-s1,d0

4.3 Field of application

This classification is valid for the following parameters defining the product described in point 2.2.

5. Limitations

This classification document does not represent type approval or certification of the product. The assigned classification remains valid as long as:

	REACTION TO FIRE CLASSIFICATION REPORT	<i>Formularz KSZ-7.8/F-42 A/20.10.2022 Page 4 of 4</i>
---	---	--

- The test method will not be changed.
- The product standard or technical approval will not be changed.
- There will be no structural or material changes influencing the properties of the tested material.

SIGNED

APPROVED

signature of person undertaking classification

signature of person authorizing this report